

INDOOR PYROTECHNICS PERMIT REQUIREMENTS

1. All safety rules specified in NFPA 1126 shall be complied with.
2. All material shall be as specified by content of plan which has been approved by the Reno Fire Department.
3. All pyrotechnic products shall be limited to indoor theatrical use. No class B & C types allowed.
4. No fallout will be allowed.
5. A fire watch must be provided during the show and for a minimum of ½ hour after the performance.
6. The operator must hold a current Nevada Licenses Pyrotechnic Operator's License.
7. The Nevada Licensed Pyrotechnic Operator shall verify that the performance site is free of any pyrotechnic devices or materials.
8. Provide two 2A10BC fire extinguishers that have a current State of Nevada seal.
9. Contact Reno Fire Department Dispatch at 334-2306 prior to show.
10. This permit shall be posted next to the launch site.

Additional requirements may be necessary based upon inspection and review of this event.